

CheckFire Ltd
Sir Alfred Owen Way
Pontygwindy Industrial Estate
Caerphilly CF83 3HU

Tel 029 2086 8333
Fax 029 2085 0627
Email sales@checkfire.co.uk

www.checkfire.co.uk

OFFICIAL RECALL NOTICE

18th August 2016



Product Code: C02EA Description: Aluminium CommanderEdge Range 2kg CO2 Extinguisher (as pictured above)

Checkfire would like to inform the Fire Extinguisher trade of a possible product failure (where the valve has ejected from the cylinder whilst under pressure). Investigation has proved that in three cases there is Pb gathering in the valve raw material. **The batch in question has a manufacture date of 2016/01.** Where these extinguishers are identified please telephone Cameron Robins or Darren Lucas on 029 2086 8333 or email cameron@checkfire.co.uk or darren@checkfire.co.uk and appropriate action will be taken.

No other batches were affected by this defect.

Signed

Cameron Robins
Purchasing Manager
For an on behalf of **CHECKFIRE**